



Product Service

CERTIFICATE

No. B 058849 0020 Rev. 01

Holder of Certificate: **Bel Fuse, Inc.**
300 Executive Drive, Suite 300
West Orange NJ 07052
USA

Certification Mark:



Product: **Tubular fuses**
(Miniature fuse-links for special applications)

The product was tested on a voluntary basis and complies with the essential requirements. The certification mark shown above can be affixed on the product. It is not permitted to alter the certification mark in any way. In addition, the certification holder must not transfer the certificate to third parties. This certificate is valid until the listed date, unless it is cancelled earlier. All applicable requirements of the testing and certification regulations of TÜV SÜD Group have to be complied. For details see: www.tuvsud.com/ps-cert

Test report no.: 64105180174805C

Valid until: 2028-07-17

Date, 2023-11-20

(Martin Ma)



Product Service

CERTIFICATE

No. B 058849 0020 Rev. 01

Model(s): **0ADKC, 0ADKP**

Parameters:

Rated voltage:	420VAC/DC, 500VAC/DC
Rated current:	1A, 1.6A, 2A, 3.15A, 4A, 5A, 6.3A, 8A, 10A, 12A, 12.5A, 15A, 16A
Rated breaking capacity:	AC: 500A (for rated current: 1A, 1.6A, 2A, 3.15A, 4A, 5A, 6.3A, 8A, 10A, power factor \geq 0.95) 200A (for rated current: 12A, 12.5A, 15A, 16A, power factor \geq 0.95) DC: 1000A (for rated current: 1A, 1.6A, 2A, 3.15A, 4A, 5A, 8A, 10A, 12A, 12.5A, 15A, 16A, time constant \leq 1ms)
Time/current characteristics:	$t_2 \leq 1h/2.1I_N$, $t_8 \leq 1s/10I_N$
Size:	5 x 20 mm
Altitude:	Not exceed 2000m

Tested according to: EN 60127-1:2006/A2:2015
EN 60127-7:2016
IEC 60127-1:2006/AMD2:2015
IEC 60127-7:2015